

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1501:119 Page 1 of 1

CATEGORY: Misc. Device/Control Unit Accessories

LISTEE: *Edwards Signaling, 90 Fieldstone Court, Cheshire, CT 06410
Contact: David Mazur (203) 699-3000 Fax (203) 699-3100

DESIGN: Models EBPS10, EBPS10/220, EBPS6 EBPS6/220, booster power supplies. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: EBPS6, EBPS10: 120 VAC
EBPS6/220, EBPS10/220: 220 VAC

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. All installations must be in accordance with NFPA 72, 1999 Edition.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as booster power supply for use with listee's separately listed compatible fire alarm control units to extend the notification appliances circuit.

XLF: 7300-1388:225

*Rev. 06-17-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 17, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager